



**LUBBOCK POWER & LIGHT
PURCHASING DEPARTMENT
1314 AVENUE K
LUBBOCK, TEXAS 79401**

ADDENDUM #1

BID NUMBER: RFP 7101-25-01

TITLE: LP&L Class Room Training Facility Construction Services

CLOSE DATE: January 9, 2025 at 2:00 p.m. CST

DATE ISSUED: December 20, 2024

All requests for additional information or clarification must be submitted in writing and directed to:

Bonfire Vendor Discussion Tab

The following items take precedence over requirements for the above named Request for Proposal (RFP). Where any item called for in the RFP documents is supplemented here, the original requirements, not affected by this addendum, shall remain in effect.

Questions and Answers, please see answers in red.

1. Equipment is spec Lennox – can we provide alternate equipment and what is acceptable? **Yes, we can accept alternate equipment. Any alternatives must meet or exceed the specifications outlined for the Lennox equipment, including performance, energy efficiency, warranty, and compatibility. Acceptable alternatives could include brands like Trane, Carrier, or Rheem, provided their models align with the project’s requirements for capacity, SEER rating, sound levels, and installation compatibility.**
2. Plans call for R410a refrigerant – with the proposed refrigerant change in 2025 not sure we will be able to get R410a equipment will have to use R32 or R454b is there a preference? **No.**

Thank You,

Felix Orta CTCD, CTCM
Purchasing Manager Electric Utilities